



Cursor A 2009/09/19 7:00'00
 Cursor B 2009/09/22 14:00'00 A<-->B 3 07:00'00

Calculation Range from 2009/09/12 12:59'50
 to 2009/09/25 23:00'11

屋上面と直下天井懐内比較

ch	Name	Interval	Sample	CursorA	CursorB	A<-->B	Max.	Min.	Avg.	Unit
1	RF-EDP-SD表面	60min.	323	18.4	40.6	22.2	40.8	18.0	26.6	°C
2	RF-未塗装表面	60min.	323	-----	-----	-----	53.9	21.5	33.3	°C
3	天井懐-EDP-SD下部	60min.	323	24.2	29.7	5.5	31.7	22.6	27.1	°C
4	天井懐-未塗装下部	60min.	323	-----	-----	-----	38.9	22.9	32.0	°C
5	腰壁-EDP-SD	60min.	323	-----	-----	-----	38.6	22.8	28.8	°C
6	腰壁-既設塗装面	60min.	323	-----	-----	-----	42.9	22.7	30.6	°C